



Republic of the Philippines

Office of the Solicitor General

134 Amorsolo St., Legaspi Village, Makati City
Tel No. 8988-1674 loc777 / Telefax No. 8813-11-74
Website: www.osg.gov.ph

Invitation for Negotiated Procurement

PROCUREMENT AND DELIVERY OF PORTABLE MEDICAL GRADE AIR PURIFIER UNITS FOR THE OFFICE OF THE SOLICITOR GENERAL

In view of two (2) failed biddings, the **Office of the Solicitor General (OSG)**, through its Bids and Awards Committee (BAC) invites interested bidder/s to participate in the Negotiated Procurement for the **Procurement and Delivery of Portable Medical Grade Air Purifier Units for the Office of the Solicitor General** with an Approved Budget for the Contract (ABC) to payments under the contract for:

Item	Purchase Request No.#	Description	Approved Budget for the Contract (ABC)
1 Lot	OSG PR# 021-11-197	Procurement and Delivery of Portable Medical Grade Air Purifier Units for the Office of the Solicitor General.	₱4,680,000.00

In accordance with Section 53.1 Two Failed Bidding as specified in the Revised Implementing Rules and Regulations (IRR) of Republic Act (RA 9184), otherwise known as the "Government Procurement Reform Act".

The negotiation was conducted last **July 11, 2022, 01:30p.m.** at **9th floor, Padilla Hall, OSG Building, 134 Amorsolo St., Legaspi Village, Makati City** and *via Microsoft Teams* video conference.

The Office of the Solicitor General, through its Bids and Awards Committee now invites the suppliers for the submission of eligibility, technical, and financial documents for the Negotiated Procurement (Two Failed Bidding) Procurement and Delivery of Portable Medical Grade Air Purifier Units for the Office of the Solicitor General. Interested bidders may submit the required documents **from August 31, 2022 to September 13, 2022, 1:25p.m.** at 134 Amorsolo Street, Legaspi Village, Makati City, from Monday to Friday (except holidays) at 8:00AM to 04:00PM.

Bid Opening shall be on **1:30 p.m. September 13, 2022 at the 9th Floor, Padilla Hall, OSG Building, 134 Amorsolo St. Legaspi Village, Makati City** and/or *via Microsoft Teams*. Bids will be opened in the presence of the bidders' representatives who choose to personally attend the activity.

Bidders are required to submit the following requirements:

- Eligibility Requirements: PhilGEPS Platinum Certificate or Registration Number; Business Permit (CY 2022); Income/Business Tax Return; and Omnibus Sworn Statement.
- Technical Requirements: Brochure of the offered product/model; Statement of Compliance in the Terms of Reference; and Documents required or stated in the Terms of Reference
- Financial Requirements: Financial Proposal (including cost per unit).

For more details on this procurement, please refer to the attached **Terms of Reference**.

For **Microsoft Teams** video conference invite, please email to osg_procurement2@gmail.com your name, designation, email address, company name, & the name of the project you are interested to join.

The **OSG** reserves the right to accept or reject any offer, to annul the negotiation process and to reject all offers at any time prior to contract award, without thereby incurring liability to affected bidder/s.

For further information, please refer to:

Christian D. Buat

ADMIN Division – Procurement Section / BAC Sec
Office of the Solicitor General
OSG Building, 134 Amorsolo St., Legaspi Village, Makati City 1229
E-mail Address: osg_procurement2@gmail.com
Tel No. (02) 8988-1674 loc. 777 / (02) 8836-3314 / Telefax No. (02) 8813-1174
Website: <https://osg.gov.ph/page?call=proc-biditems>


SHARON E. MILLAN-DECANO
Assistant Solicitor General
Chairperson, Bids and Awards Committee

TERMS OF REFERENCE

PROCUREMENT AND DELIVERY OF PORTABLE MEDICAL GRADE AIR PURIFIER UNITS FOR THE OFFICE OF THE SOLICITOR GENERAL (OSG), MAKATI CITY

APPROVED BUDGET FOR THE CONTRACT (ABC) ON OFFICE EQUIPMENT (MEDICAL GRADE AIR PURIFIERS)

Four Million Six Hundred Eighty Thousand Pesos (Php4,680,000.00), inclusive of all applicable government taxes and charges.

TECHNICAL SPECIFICATIONS FOR OFFICE EQUIPMENT (MEDICAL GRADE AIR PURIFIERS)

Filter Type	HEPA Filter
HEPA Rating	At least H13
Filter efficiency / Purification rate	At least 99.95%
*Can filter at least 0.3 microns	
Optimal Area Capacity	30- 50 sqm
Voltage/Frequency	220-240V
Color	White, black, or grey
Noise Level (dBA)	Silent type (maximum of 50 dBA)
CADR Rating (Clean Air Delivery Rate)	At least 220 m3/h
Wind speed switch	Low, medium and high speed
Stages of Purification	Multiple stages of purification with HEPA filter
MERV Rating	MERV 16 (Can filter 0.3 microns)
Maintenance	Washable filter or replaceable filter